



DEAN D. EFSTATHIOU, Acting Director

COUNTY OF LOS ANGELES

DEPARTMENT OF PUBLIC WORKS

"To Enrich Lives Through Effective and Caring Service"

900 SOUTH FREMONT AVENUE
ALHAMBRA, CALIFORNIA 91803-1331
Telephone: (626) 458-5100
<http://dpw.lacounty.gov>

ADDRESS ALL CORRESPONDENCE TO:
P.O. BOX 1460
ALHAMBRA, CALIFORNIA 91802-1460

IN REPLY PLEASE
REFER TO FILE: **A-0**

August 5, 2008

TO: Each Supervisor

FROM: Dean D. Efstathiou *DE*
Acting Director of Public Works

CHINO HILLS EARTHQUAKE COUNTY FACILITIES REPORT AUGUST 05, 2008

Since our last report, Public Works and the Internal Services Department have continued coordinating and communicating with the Chief Executive Office as we receive Initial Damage Assessment Reports (IDARs) and respond to requests for inspection of County facilities. Based on the IDARs and inspections performed thus far, the Chino Hills Earthquake has not resulted in any significant damage to County facilities.

We have attached an updated facility inspection report summary for your reference and will continue to update you on our progress in this regard.

JJW:mel
C:\MYFILES\WILLIAMS\CHINO HILLS EARTHQUAKE REPORT

Attach.

cc: Chief Executive Office (William T Fujioka, John Edmisten, Lari Sheehan,
Jan Takata)
Executive Office
Internal Services Department (Tom Tindall, Dave Yamashita)

LOS ANGELES COUNTY DEPARTMENT OF PUBLIC WORKS and INTERNAL SERVICES DEPARTMENT

CHINO HILLS EARTHQUAKE - FACILITY STATUS REPORT								
S/T RESP. COMMITTEE REQUEST ID	FACILITY NAME	PURPOSE OF REQUEST	DATE REQUEST ASSIGNED FOR EVALUATION	CURRENT POSTING CLASSIFICATION	INITIAL EVALUATION DATE	INITIAL EVALUATION TIME	DAMAGE REPORT	DAMAGE OBSERVED
1	Department of Public Works Headquarters 900 South Fremont Avenue Alhambra, California 91803	Rapid Evaluation	7/29/08	Green	07/29/2008	12:35 p.m.	Minor cracks in concrete.	Minor cracks in concrete
2	Long Beach Courthouse 415 West Ocean Blvd Long Beach, California 90802	Rapid Evaluation	7/29/08	Green	07/29/2008	3:15 p.m.	Possible structural damage.	Minor non-structural
3	Clara Shortridge Foltz Criminal Justice 210 West Temple Street Los Angeles, California 90012	Rapid Evaluation	7/29/08	Green	07/29/2008	6:23 p.m.	Cracks in stairwells, not previously here.	Minor cracks to drywall in stairwell.
4	Alhambra Courthouse 150 West Commonwealth Avenue Alhambra, California 91801	Rapid Evaluation	7/29/08	Green	07/30/2008	11:00 a.m.	Fall ceilings tiles limited damage to ceiling supports.	Crack in drywall and water leak.
5	Department of Children and Family Services 1373 East Center Court Drive Covina, California 91724	Rapid Evaluation	7/29/08	Green	07/29/2008	5:45 p.m.	Minor structural damage.	Minor cracks to drywall in stairwells and along doorways.
6	Probation Department 200 West Woodard Alhambra, California 91801	Rapid Evaluation	7/29/08	Green	07/29/2008	4:30 p.m.	Possible structural damage.	No new damage observed.
7	Fire Department Headquarters 1320 North Eastern Avenue Los Angeles, California 90063	Rapid Evaluation	7/29/08	Green	07/29/2008	4:00 p.m.	None, but verify safety of the facility.	No new damage observed.
8	Whittier Courthouse 7339 Painter Avenue Whittier, California 90602	Rapid Evaluation	07/30/2008	Green	7/30/08	12:15 p.m.	Possible structural damage.	Minor cracks to concrete shear wall.
9	El Monte Courthouse 11234 East Valley Blvd El Monte, California 91731	Rapid Evaluation	7/30/08	Green	7/30/08	1:30 p.m.	Fallen ceiling tiles. Limited damage to ceiling supports.	Minor damage to drywall.
10	Auto Park 18 140 North Grand Avenue Los Angeles, California 90012	Rapid Evaluation	7/30/08	Green	7/30/08	4:00 p.m.	Loosening of existing damage.	No new damage attributed to the earthquake.
11	Downey Data Center 9150 East Imperial Highway Downey, California 90650	Detailed Evaluation	7/31/08	Green	7/31/08	5:30 p.m.	Damage to North, East, and Southwest Stairwell.	Minor cracks on on tilt-up walls, spelling of concrete at upper corners, suspended ceiling damage.
12	Norwalk Region Library 12350 Imperia Highway Norwalk, California 90650	Detailed Evaluation	7/31/08	Green/Yellow	8/4/08	In progress	Damage to decorative dish, suspended from ceiling. Area under this dish has been cordoned off to protect public safety.	Possible damage to decorative dish support, suspended from ceiling. Area under this dish has been cordoned off to protect public safety. Follow-up evaluation is needed.
13	Whittier Parking Structure 6721 Brigtet Ave Whittier, California	Rapid Evaluation	7/31/08	Green	8/1/08	4:30 p.m.	Possible Structural damage.	Minor new cracks, some existing cracks, corrosion.
14	Department of Health Services 5555 Ferguson Drive Commerce, California 90022	Rapid Evaluation	8/1/08	Green	8/4/08	In progress	Interior and Exterior wall and ceilings cracked and buckled.	Cracks in a ceiling, and masonry wall. Follow-up evaluation is needed.
15	Pomona Superior Court 400 Civic Center Plaza Pomona, California 91766	Rapid Evaluation	8/5/08	Scheduling			Minor structural damage.	
16	Parks and Recreation HQ 433 South Vermont Ave Los Angeles, CA 90020	Phone Report	8/5/08	Green	7/29/08	7:00pm	Ceiling tile movement, Air Quality testing performed, results OK, chrysotile wash underway	